

**TEXAS COMMISSION ON JAIL STANDARDS
JAIL INSPECTION REPORT**

Facility Name: Bastrop County Jail

Date:

April 19-20, 2017

Item	Section	Paragraph	Comments
1	263	.55	Inspections, Maintenance, Testing. All life safety equipment shall be inspected, maintained, and tested by persons qualified to do so (whether under vendor contract, by state or private agency or otherwise) in order that such equipment shall be safe, secure, and fully operative at all times. The fire panel at the courthouse is showing trouble and cannot reset to normal mode.
2	273	.5(a)(2)	Identification. Procedures for intake screening to identify inmates who are known to be or observed to be mentally disabled and/or potentially suicidal and procedures for compliance with Code of Criminal Procedure Article 16.22 and referrals to available mental health officials During the review the of the inmate medical documentation, this inspector observed that on numerous occasions neither the magistrate nor MHMR were properly notified according to the approved mental health screening tool and Art. 16.22 of the CCP.



Fred St. Amant, T.C.J.S. Inspector