

**TEXAS COMMISSION ON JAIL STANDARDS  
JAIL INSPECTION REPORT**

**Facility Name:** Baylor County Jail-Court Holding Cells

**April 14, 2017**

Item	Section	Paragraph	Comments
1	263	.41	<p>Training of staff for emergency situations shall be provided immediately upon employment and no less than each calendar quarter for all jail personnel to include fire, emergency, evacuation drills, and location and use of equipment.</p> <p><b>It was determined that staff has not received training for fire, emergency, and evacuation drills or the location and use of life safety equipment for the first quarter of 2017.</b></p>
2	263	.42	<p>Each facility, after consultation with the local fire department or Texas Commission on Fire Protection, shall have and implement a written plan, approved by the Commission, for fire prevention and a fire hazard inspection checklist which shall be evaluated no less than each calendar quarter. The facility shall be inspected annually by a local fire official.</p> <p><b>While reviewing life safety documentation, it was determined the last time the facility had been inspected by a certified fire official was on April 5, 2016. The administration advised they would get the inspection completed as soon as possible.</b></p>
3	263	.42	<p>Each facility, after consultation with the local fire department or Texas Commission on Fire Protection, shall have and implement a written plan, approved by the Commission, for fire prevention and a fire hazard inspection checklist which shall be evaluated no less than each calendar quarter. The facility shall be inspected annually by a local fire official.</p> <p><b>It was determined that staff has not been conducting quarterly fire prevention inspections as required by minimum jail standards. The last fire prevention inspection was conducted on December 7, 2015.</b></p>



**Shane Sowell - TCJS-Inspector**