

**TEXAS COMMISSION ON JAIL STANDARDS
JAIL INSPECTION REPORT**

Facility Name: Robertson Co. Jail

Date: February 28, 2019

Item	Section	Paragraph	Comments
1	259	.156	Power Operated Locks. Power operated locks shall be motor, solenoid, or pneumatic type and provide electrical control unlocking, key unlocking by manual operation, and automatic mechanical deadlocking of doors upon closing.

The power operated locks, on both doors, that allow entry into the jail from the sally port are inoperable. The jail staff have to use two different keys to open the doors. Key only access is not allowed by minimum jail standards.


Shannon J. Herklotz, Assistant Director