

**TEXAS COMMISSION ON JAIL STANDARDS
JAIL INSPECTION REPORT**

Facility Name: Collingsworth Co. Jail

Date:

September 19, 2017

Item	Section	Paragraph	Comments
1	263	.42	<p>The facility shall be inspected annually by a local fire official.</p> <p>On date of inspection, it was determined the last Fire Marshal inspection was conducted on January 8, 2016 which is past the one year mark and is a direct violation of minimum jail standards.</p>
2	279	.1 (2)	<p>Food preparation areas shall be inspected at least annually by health authorities and record kept for each inspection</p> <p>During the review of facility paperwork, it was determined the last Health Inspection was conducted on February 9, 2016 which is past the one year mark and is a direct violation of minimum jail standards.</p>


TCJS Inspector Shane Sowell