

**TEXAS COMMISSION ON JAIL STANDARDS
JAIL INSPECTION REPORT**


Facility Name: Hardin County Jail

Date:

April 24, 2018

Item	Section	Paragraph	Comments
1	279	.3	Preventive maintenance, to include necessary repairs, shall be conducted to ensure a safe, secure, and sanitary facility.

During the walk-through, this inspector observed several inoperable lights, inoperable sinks, multiple receptacle face plates missing, electrical boxes that were hanging with exposed wiring, shower curtains hanging from smoke detectors and a shortage of inmate mattresses. There were television observed to be hanging by sheets in some inmate cells and not properly mounted.



Jennifer Shumake, TCJS Inspector