

**TEXAS COMMISSION ON JAIL STANDARDS
JAIL INSPECTION REPORT**

Facility Name: Goliad County Jail

Date:


November 17, 2017

Item	Section	Paragraph	Comments
1	263	.42	Fire Prevention Plan. Each facility, after consultation with the local fire department or Texas Commission on Fire Protection, shall have and implement a written plan, approved by the Commission, for fire prevention and a fire hazard inspection checklist which shall be evaluated no less than each calendar quarter. The facility shall be inspected annually by a local fire official.

The Goliad Co. Jail has not had an annual inspection by a certified fire official since March 3, 2016 which is a violation of minimum jail standards.



Phillip Bosquez, T.C.J.S. Inspector



Jennifer Shumake, T.C.J.S. Inspector