

**TEXAS COMMISSION ON JAIL STANDARDS  
JAIL INSPECTION REPORT**

**Facility Name:** Shackelford Co. Jail

**Date:**

June 4, 2019

Item	Section	Paragraph	Comments
1	263	.41	<p>Training and Drills. Training of staff for emergency situations shall be provided immediately upon employment and no less than each calendar quarter for all jail personnel to include fire, emergency, evacuation drills, and location and use of equipment.</p> <p><b>The fire drill and air pack training was not conducted during the 4th quarter of 2018.</b></p>
2	263	.42	<p>Fire Prevention Plan. Each facility, after consultation with the local fire department or Texas Commission on Fire Protection, shall have and implement a written plan, approved by the Commission, for fire prevention and a fire hazard inspection checklist which shall be evaluated no less than each calendar quarter. The facility shall be inspected annually by a local fire official.</p> <p><b>The fire marshal inspection was last conducted on April 12, 2018 which places the facility two months past due of the required, annual inspection.</b></p>
3	263	.55	<p>All life safety equipment shall be inspected, maintained, and tested by persons qualified to do so (whether under vendor contract, by state or private agency, or otherwise) in order that such equipment shall be safe, secure, and fully operative at all times.</p> <p><b>The Ansul Hood System was last inspected on March 2017.</b></p>
4	271	.7	<p>Classification Audit. The plan shall provide that an annual, internal audit shall be conducted on the classification system. Audit records shall be maintained for Commission review. The audit shall assess the following features of the objective classification system: (1) inmates are classified prior to placement in inmate housing; (2) inmates are housed according to their assigned custody levels; (3) the override rate is acceptable; and (4) classification instruments are completed in an accurate and timely manner.</p> <p><b>A classification audit has not been conducted since April of 2018 which exceeds the minimum annual requirement.</b></p>



**Jason Jouett, TCJS Inspector**