

**TEXAS COMMISSION ON JAIL STANDARDS
JAIL INSPECTION REPORT**

Facility Name: San Augustine County Jail

Date:

January 13, 2020

Item	Section	Paragraph	Comments
1	279	.3	Preventive maintenance, to include necessary repairs, shall be conducted to ensure a safe, secure, and sanitary facility.

During a walk-through of the jail, it was determined that the control board is falsely indicating certain facility doors are secured when they are unsecured which is an officer safety concern.

-William Phariss

William T. Phariss, TCJS Inspector