

**TEXAS COMMISSION ON JAIL STANDARDS  
JAIL INSPECTION REPORT**

**Facility Name:** Live Oak County Jail

**Date:**


January 4, 2022

Item	Section	Paragraph	Comments
1	263	.55	All life safety shall be inspected, maintained, and tested by persons qualified to do so (whether under vendor contract, by state or private agency or otherwise) in order that such equipment shall be safe, secure, and fully operative at all times. <b>On the day of inspection, the fire panel was in "trouble mode" and could not be reset to normal mode.</b>
2	263	.55	All life safety shall be inspected, maintained, and tested by persons qualified to do so (whether under vendor contract, by state or private agency or otherwise) in order that such equipment shall be safe, secure, and fully operative at all times. <b>During the review of the life safety documentation, it was determined that the last Fire Marshall Inspection was conducted on September 2, 2020. This places the Fire Marshall Inspection past due by sixteen months.</b>

**RECEIVED**

JAN 05 2022

TEXAS COMMISSION  
ON JAIL STANDARDS



**Earnestine Sanders, TCJS Inspector**