

**Texas Commission on Jail Standards
JAIL INSPECTION REPORT**

Facility Name: Nacogdoches Co. Jail

Date:

January 15, 2022

Item	Section	Paragraph	Comments
1	259	.134, .135	Multiple occupancy cells shall contain two to eight bunks and not less than 40 square feet of clear floor space for the first bunk plus 18 square feet of clear floor space for each additional bunk. Each multiple occupancy cell shall have one toilet and lavatory. //Dormitories shall contain 9-48 bunks. Dormitories shall contain not less than 40 square feet of clear floor space for the first bunk plus 18 square feet of clear floor space for each additional bunk. Each dormitory shall have adequate toilets, lavatories and may include showers.

A review of documentation shows that Nacogdoches County exceeded their rated housing capacity on multiple days: January 11, 2022, January 12, 2022 and January 13, 2022


Michael Gravitt, TCJS Inspector

RECEIVED
JAN 18 2022
TEXAS COMMISSION
ON JAIL STANDARDS